



Produktprüfung
Zertifizierung
Qualitätssicherung

eco
INSTITUT

Attestation

Based on the test report No. 39250-003 dated 2013-03-01
“Emission tests VOC (TVOC), SVOC, Aldehyde/Ketones (incl. Formaldehyd)“

Entrance mat Style Recoarse II, Color 8413

Amtico International Ltd. UK

Evaluation of the emissions test results according to AgBB (Committee for Health-related Evaluation of Building Products) and DIBt (German Institute of Structural Engineering) guidelines

Carcinogenic substances have not been detected after 3 and 7 days.

The sum of VOC (defined as TVOC) after 3 days was below 10 mg/m^3 .

The sum of VOC (defined as TVOC) after 7 days was below 0.5 mg/m^3 .

The sum of SVOC after 7 days was below the limit of 0.05 mg/m^3 .

The R-Value after 7 days calculated with single VOC concentrations above $5 \text{ } \mu\text{g/m}^3$ was below the limit of 0.5.

The sum of VOC without LCI after 3 and 7 days was below the limit of 0.05 mg/m^3 .

Sampling, testing and evaluation were performed according to
ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 and ISO 16017:

The tested product complies with the requirements of DIBt (10/2010) in combination with the NIK values from AgBB (2012) for use in indoor environment.

Cologne, 8th March 2013
eco-INSTITUT GmbH

Ralph Nitsche
(Project manager)



eco-INSTITUT GmbH
Sachsenring 69
50677 Köln

Fon +49-(0)221-931 245 -0
Fax +49-(0)221-931 245 -33

www.eco-institut.de
www.eco-info.de
info@eco-institut.de

