



Produktprüfung  
Zertifizierung  
Qualitätssicherung

**eco**  
INSTITUT

# Attestation

Based on the test report No. 39250-002 dated 2013-03-01  
"Emission tests VOC (TVOC), SVOC, Aldehyde/Ketones (incl. Formaldehyde)"

**Entrance mat Style Take Back, color 1419**

**Amtico International Ltd. UK**

Evaluation of the emissions test results according to AgBB (Committee for Health-related Evaluation of Building Products) and DIBt (German Institute of Structural Engineering) guidelines

Carcinogenic substances have not been detected after 3 and 7 days.

The sum of VOC (defined as TVOC) after 3 days was below  $10 \text{ mg/m}^3$ .

The sum of VOC (defined as TVOC) after 7 days was below  $0.5 \text{ mg/m}^3$ .

The sum of SVOC after 7 days was below the limit of  $0.05 \text{ mg/m}^3$ .

The R-Value after 7 days calculated with single VOC concentrations above  $5 \text{ } \mu\text{g/m}^3$  was below the limit of 0.5.

The sum of VOC without LCI after 3 and 7 days was below the limit of  $0.05 \text{ mg/m}^3$ .

Sampling, testing and evaluation were performed according to  
ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 and ISO 16017:

**The tested product complies with the requirements of DIBt (10/2010) in combination with the NIK values from AgBB (2012) for use in indoor environment.**

Cologne, 8<sup>th</sup> March 2013  
eco-INSTITUT GmbH

Ralph Nitsche  
(Project manager)



eco-INSTITUT GmbH  
Sachsenring 69  
50677 Köln

Fon +49-(0)221-931 245 -0  
Fax +49-(0)221-931 245 -33

www.eco-institut.de  
www.eco-info.de  
info@eco-institut.de

